








No.	Name	Drawing No.	Qty.
7	Nozzle hook ,G	2530-027	1
6	Holder ,A	2530-022A	1
5	NUT,M14x7	02-E-020	1
4	Nameplate,212x1.5x4	02-E-019	1
3	Nylon Washer,30x14.5x3	02-E-018	1
2	Manual Waterway Assembly, 02-E	02-E-002C	1
1	Hose Reel Assembly,02-E	02-E-001E	1

Technical Requirements:
1. Hose reel W.P 1.2MPa;
2.No burst,leakage after 1.8MPa pressure test;
The hose reel can still work properly.

NO.	Original Size	Modified	Revisor	Auditor	Date
△					
△					
△					
△					
△					
△					
△					

Name	Brandslanghaspel 20-25-30m 3/4” ∅ schijf 700mm			Approved	C. Pollet 2013.07.13
Material		Surface Treatment		Design	2013.07.13
Drawing Number	02-K5	Unit	mm	Draw	2013.07.13
		Proportion	1:1		
crico				Revision	A