








No.	Name	Drawing No.	Qty.
7	Nozzle hook ,G	2530-027	1
6	Holder,A	2530-022A	1
5	NUT,M14x7	02-E-020	1
4	Nameplate,212x1.5x4	02-E-019	1
3	Nylon Washer,30x14.5x2	02-E-018	1
2	Manual Waterway Assembly 02-E	02-E-002AB	1
1	Hose Reel Assembly 02-E		1

Technical Requirements:

1. Hose reel W.P 1.2MPa;
2. No burst,leakage after 1.8MPa pressure test;
The hose reel can still work properly.

NO.	Original Size	Modified	Revisor	Auditor	Date					
△						Name	Brandslanghaspel 20m 3/4” ∅ schijf 600mm		Approve	C. Pollet
△										
△						Material		The number of drawing		Design
△										2024.08.15
△						Drawing No.	02-K6	Unit	mm	Draw
△								Proportion	1:6	2024.08.15
△						crico			Revision	A